



Waterline Technology®

1904 Industrial Way 419-529-3949 direct
 Caldwell, ID 83605 419-529-8484 fax
 sales@waterlinetechnology.com www.waterlinetechnology.com

Performance Data Sheet

AlwaysFresh®
 Water the way you want it™

HFC-1000 Drinking Water System

HFC-1000 Replacement Cartridge Part No. RC-HFC-1000

Read this Performance Data Sheet and compare the capabilities of this unit with your actual drinking water needs. Bear in mind that this system is your final barrier of protection against unknown contaminant's which may be affecting your water supply.

Water Testing: If your water has an aesthetic problem - one you can see, taste or smell - your senses are your most reliable resource. If you have read about or suspect volatile organic chemicals, chlorinated by-products or lead contamination you may want to have your water tested. But be careful...water testing can be expensive. A complete analysis of hundreds of contaminant's that may be in water can cost hundreds of dollars, or even thousands of dollars. A betterand lessexpensive alternative is to have your water tested only for common water contaminant's, or for contaminant's you have read about or know are likely to be in your water. Additionally, they may not be as conclusive as you might like, since contaminant levels can vary from day to day and week to week. Taking a specific sample at any given time may yield a falsely good (or bad) result.

Private water supply: Having your water tested may be your only way of knowing for sure what health related contaminant's might be present. Local health departments only test for a limited range of contaminant's like bacteria to approve the well for potable water.

Public Water supply: Which service more that 3/4 of the population in America are already tested, following state and federal guidelines and law and are available for the asking from your water supply company/utility. These guidelines and laws do not cover every known contaminant that may be affecting your water source.

Water the Way you Want It: Many times it is a better investment, both in terms of money and peace of mind, to invest in a quality drinking water system that solves a wide range of problems that you may or may not have or know about.

Health Claim Performance Certified by WQA & IAMPO RT

This system has been tested to NSF/ANSI Standards 42, 53 for the reduction of the substances listed below. The concentration of the indicated substances in water entering the system was reduced to a concentration less than or equal to the permissible limit for water leaving the system, as specified in NSF/ANSI 42 & 53, 401, NSF/ANSI/CAN 372

Substance	Influent Challenge Concentration	Min % Reduction Requirement/ Max Permissible Product Water Concentration	Minimum Reduction	Average Reduction
Standard 42 - Aesthetic Effects				
Chlorine	2.0 mg/L +10%	>=50%	N/A	99.0%
Particulate				
Class 1 Particles 0.5-1.0 micron	>10,000 particles / mL	>=85%	93.0%	97.0%
Turbidity	11 NTU			97.7%
Standard 53 - Health Effects				
Chloroform (VOC surrogate chemical)	300ug/L +10%	>= 95%	99.8%	99.8%
MTBE (Methyl tert-Butyl Ether)	0.015mg/L +20%	<=0.005mg/L	N/A	95.1%
TTHM (as chloroform)	0.450mg/L +10%	<=0.080/mg/L	99.9%	99.9%
Turbidity	10.0-12.0 NTU s	<=0.5NTU	97.7%	99.05%
Cysts	>50,000 /L	>= 99.95%	N/A	99.98%
Lead 6.5 pH	0.15mg/L +10%	<=0.010	98.2%	99.6%
Lead 8.5 pH	0.15mg/L +10%	<=0.010	99.7%	99.9%
Perfluorooctanoic acid (PFOA) & Perfluorooctane sulfonate (PFOS)*				
PFOA/PFOS	1500 ng/L +10%	70 ng/L	96.0%	98.1%
NSF/ANSI/CAN Std 372 -Low Lead Content 0.25% wetted parts				
NSF/ANSI Std 401 - Reduction of Microplastics				

* Certified by IAMPO RT

Operating Specifications

*Capacity: 500 gallons (1890L)

*Pressure requirements: 30-125 psi (2.1-8.6 bar),non-shock

*Temperature: 35-100 degrees F (2-38 degrees C)

*Flow Rate: 1.5 gpm (5.7 Lpm)

(1) not certified by WQA,

"The end-user should not attempt to regenerate and reuse spent media from this product"

Performance Data Sheet Reduction Claims for Organic Chemicals Included by Surrogate Testing

Substance	Influent Challenge Concentration mg/L	Maximum permissible Product Water Concentration mg/L
alachlor	0.050	0.001
atrazine	0.100	0.003
benzene	0.081	0.001
carbofuran	0.190	0.001
carbon tetrachloride	0.078	0.0018
Chlorobenzene	0.077	0.001
chloropicrin	0.015	0.0002
2,4-D	0.110	0.0017
dibromochloropane (DBCP)	0.062	0.00002
o-dichlorobenzene	0.080	0.001
p-dichlorobenzene	0.040	0.001
1,2-dichloroethane	0.088	0.0048
1,1-dichloroethylene	0.083	0.001
ois-1,2-dichloroethylene	0.170	0.0005
trans-1,2-dichloroethylene	0.086	0.001
1,2-dichloropropane	0.080	0.001
ois-1,3-dichloropropylene	0.079	0.001
dinoseb	0.170	0.0002
endrin	0.053	0.00059
ethylbenzene	0.088	0.001
ethylene dibromide (EDB)	0.044	0.00002
haloacetonitriles (HAN):		
bromochloroacetonitrile	0.022	0.0006
dibromoacetonitrile	0.024	0.0006
dichloroacetonitrile	0.0096	0.0002
trichloroacetonitrile	0.015	0.0003
haloketones (HK)		
1,1-dichloro-2-propanone	0.0072	0.0001
1,1,1-trichloro-2-propanone	0.0082	0.0003
heptachlor	0.25	0.00001
heptachlor epoxide	0.0107	0.0002
hexachlorobutadiene	0.044	0.001
hexahlorocyclopentadiene	0.060	0.000002
lindane	0.065	0.00001
methoxychlor	0.050	0.0001
pentachlorophenol	0.096	0.001
simazine	0.120	0.001
styrene	0.150	0.0005
1,1,2,2-tetrachloroethane	0.081	0.001
tetrachloroethylene	0.081	0.001
toluene	0.078	0.001
2,4,5-TP (silvex)	0.270	0.0016
tribromoacetic acid	0.042	0.001
1,2,4-trichlorobenzene	0.160	0.0005
1,1,1-trichloroethane	0.084	0.0046
1,1,2-trichloroethane	0.150	0.0005
trichloroethylene	0.180	0.001
trihalomethanes (includes):		
chloroform (surrogate chemical)		
bromoform	0.300	0.015
bromodichloromethane		
chlorodibromomethane		
xylenes (total)	0.070	0.001

Features of Product

- ***High Flow Rate** 1.5 gpm
- ***Exclusive & Sanitary, Quick Change Cartridge**
- ***Fine Filtration** produces a premium quality water for drinking, cooking, ice and food preparation.
- ***Reduces Chlorine taste and odor**
- ***Reduces dirt, rust, and other particulates**
- ***Reduces parasitic protozoan cysts**, such as Giardia, Entamoeba and Cryptosporidium.
- ***Reduces lead** to below Federal Action level(2)
- ***Effectively reduces methyl tertiary-butyl ether (MTBE)**
- ***Effectively reduces volatile organic chemicals (VOC's)**, including trihalomethanes (TTHM's)
- ***Effectively reduces Perfluorooctanoic acid (PFOA) & Perfluorooctane sulfonate (PFOS)**
- ***Effectively Reduces Microplastics per NSF/ANSI Std 401**
- ***Low Lead Content NSF/ANSI/CAN 372**
- ***Filter Protection** - EPA-registered, FDA-listed and NSF-certified for food and water uses: Silver Zeolite Technology blend throughout the filter using ion exchange to "manage" the silver release, giving optimum efficacy and longevity for filter protection.
- ***Limescale protection** against hard water minerals that form scale on water using appliances. (1)

(1) Not certified by IAPMO R&T

LIMITED WARRANTY



Waterline Technology warrants this product to be free of defects in workmanship or materials for twelve months from date of purchase or 24 months from date of manufacture. This warranty extends only to the original consumer and does not cover products which malfunction due to neglect or unauthorized modification. Warranty does not cover in-house labor or other labor charges.

The unit must be used in operating conditions that conform to Waterline's recommended design guidelines. This warranty will not apply if the unit is modified, repaired, or altered by someone not authorized by Waterline. We are not responsible for damage caused by accident, fire, flood, freezing, Act of God, misuse, misapplication, neglect, oxidizing agents, or operation contrary to printed instructions, or using accessories or components not recommended in our installation guide.

Systems are not warranted to perform for a water source which does not meet the conditions for use described in the installation guide or performance data sheet or other documents for these products. Water characteristics can vary seasonally or over a period of time. Waterline recommends having your water evaluated from time to time for any health-related contaminant after this unit to ensure it meets all applicable requirements and regulations for your use.

OUR OBLIGATIONS UNDER THIS WARRANTY ARE LIMITED TO THE REPAIR OR REPLACEMENT (AT WATERLINE'S DISCRETION) OF THE FAILED PARTS OF THE SYSTEM, AND WE ASSUME NO LIABILITY WHATSOEVER FOR DIRECT, INDIRECT, INCIDENTAL, CONSEQUENTIAL, SPECIAL, GENERAL OR OTHER DAMAGES INCLUDING WATER DAMAGE.

IT IS THE END USERS' RESPONSIBILITY TO ENSURE THE SYSTEM IS INSTALLED IN SUCH A MANNER THAT IN THE EVENT OF A WATER LEAK OR BREAK THAT THE WATER CAN BE AUTOMATICALLY SHUT OFF WITH LEAK SENSORS OR MONITORED BASED UPON INDIVIDUAL INSTALLATION METHODS.

To obtain warranty performance:

A: Call Technical Service at the number listed below to obtain an RGA (Return Goods Authorization Number). *No returns accepted without an RGA number* and Waterline reserves the right to dispose of any items returned without RGA after 30 days.


B: Return this product with the **RGA number clearly marked on the carton** to Waterline Technology, transportation or mail prepaid, with an attached statement giving the date and place of purchase, the nature of the defect and your return address, and if possible, your telephone number.

C: Upon receipt, Waterline Technology will examine your claim. If this warranty applies, Waterline Technology, at its option will either replace or repair this product.

D: Please send all returns or warranty questions to: Waterline Technology 1906 Industrial Way, Caldwell, ID 83605 UPS or via trackable service.

This Warranty is in lieu of all other warranties expressed or implied, written, or oral. No employee, agent, dealer, or other person is authorized to give any warranties on behalf of Waterline Technology. NOTE: Some states do not allow limitations on how long an implied warranty lasts so the above limitation may not apply to you. Similarly, some states will not allow the exclusion or limitation of consequential or incidental damages so the above limitation or exclusions may not apply to you. This warranty gives you special legal rights. You may also have other rights which may vary from state to state. Proof of purchase must accompany all merchandise returns if more than 12 months from date of Manufacture.

Ask your local distributor about the Automatic Cartridge Delivery Program.



Phone: 419.529.3949
Fax: 419.529.8484
Email: sales@waterlinetechnology.com
web site: www.waterlinetechnology.com

Form WT-060102025 warranty.

General Installation/Operation/Maintenance Requirements

- *Space required: 5 x 5 x 23 in. (13 x 13 x 53 cm) including 2.5 inches of clearance under unit for cartridge change.
- *Recommended to install vertically
- *Flush new cartridge at full flow for several minutes until water runs clear.
- * Replace cartridge when capacity is reached, or when flow becomes too slow, but at least once per year.
- *Installation instructions, and this performance data sheet available on our company website, or by request via email or USPS mail. .
- * This system must be maintained according to manufacturer's instructions, including replacement of filter cartridge. Suggested Retail \$175.75 USD

Additional important NOTES:

- * Do not use with water that is microbiologically unsafe, or of unknown quality without adequate disinfection before or after the system. Systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.
- *The contaminant's or other substances reduced by this water treatment system are not necessarily in your water.
- *Check for compliance with state and local laws and regulations.
- *System tested under standard laboratory conditions, actual performance may vary.

Buyer

Seller

Date

This system certified by IAPMO R&T to CSA B483.1, NSF/ANSI 42, 53, 401 & NSF/ANSI/CAN 372 for specific performance claims as verified below and substantiated by test data :

Std. No. 42 - Aesthetic effects

Chemical Reduction

- Taste and odor
- Chlorine Taste and odor



Mechanical Filtration

- Particulate Class 1 (0.5-1.0 micron)

Std No. 53 - Health effects

Chemical Reduction

- Lead
- MTBE
- VOC's
- TTHM's
- PFOA/PFOS*

Mechanical Filtration

- Turbidity
- Cysts

NSF/ANSI/CAN Std 372 - Low Lead Content

NSF/ANSI Std 401 - Reduction of Microplastics

California Water Boards

Certification Number 3330

This system certified by WQA to CSA B483.1, NSF/ANSI 42, 53, 401 & NSF/ANSI/CAN 372 for specific performance claims as verified above and substantiated by test data

* certified by IAPMO RT

